

CARSON CITY PURCHASING AND CONTRACTS
201 North Carson Street, Suite 3
Carson City, NV 89701
775-283-7137/FAX 887-2107

<http://www.carson.org/index.aspx?page=998>

NOTICE TO CONTRACTORS
BID #1415-019
Fleet Facility Expansion
PWP # CC-2014-289

Addendum No. 3

Please make the following additions/changes/clarifications to the above referenced project:

1. Please note that the time of the bid opening has been changed to 2:10 p.m. The date and location of the bid opening is unchanged.

The following is based on a question received September 8, 2014:

2. *Sheet P2.1, the Base Bid Plan A/P2.1, notes "Existing building to be retrofitted with fire sprinklers as part of the Base Bid." Special Conditions page SC-8 notes, "The fire protection scope of work includes the extension of the fire sprinkler system into the existing building and installing fire sprinklers throughout the existing building." Do we include the fire sprinkler work in the Base Bid or in Alternate "F"? Please clarify.*

At SC 6.2.9, delete the following sentence in its entirety "The Fire Protection scope of work includes the extension of the fire sprinkler system into the existing building and installing fire sprinklers throughout the existing building." The existing building shall be retrofitted with fire sprinklers as part of the Base Bid as shown on Sheet P2.1, Detail A/P2.1

End of Addendum 3