



**NOTES:**

1. MINIMUM CURB RETURN RADIUS SHALL BE 15 FEET UNLESS OTHERWISE APPROVED BY THE CARSON CITY ENGINEER OR PUBLIC WORKS DIRECTOR.
2. SOME STREETS MAY REQUIRE WIDER SIDEWALKS.
- △ 3. SIDEWALK ADJACENT TO TYPE 2 OR ROLLED CURB AND GUTTER SHALL BE CONSTRUCTED 5 INCHES THICK OF CONCRETE ON 6 INCHES OF AGGREGATE BASE COMPACTED TO 95%
- △ 4. SIDEWALK SHALL BE POURED NON-MONOLITHICALLY FROM CURB AND GUTTER.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION CARSON CITY
△ 1	NOTE 3 & 4	9/17	<b>TYPE "A" SIDEWALK</b>	DRAWING NO. C-5.2.2
				DATE SEP 2017
APPROVED BY:		9/17		