



NOTES: TYPICAL SECTION
NTS

1. CENTER CHECK VALVE IN VAULT.
2. MANHOLE FRAME AND COVER TO BE SOUTH BAY FOUNDRY "SBF 1900 CPH" (CLOSED PICK HOLE) OR EQUAL AND SHALL BE MARKED "WATER".
3. MANHOLES SHALL BE WATER-TIGHT.
4. COMPACT TOP 6 INCHES SUBGRADE TO 90% M.D.D. PRIOR TO PLACING BACKFILL.
5. CHECK VALVES 12 INCHES OR LARGER REQUIRE SPECIAL DESIGN AND APPROVAL BY THE CARSON CITY ENGINEER OR PUBLIC WORKS DIRECTOR.
6. CHECK VALVES INSTALLED ON PRIVATE FIRE HYDRANT LINES ARE OWNED, OPERATED AND MAINTAINED BY THE PROPERTY OWNER

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	NOTE 3	9/17	<h1>CHECK VALVE</h1>	CARSON CITY
				DRAWING NO.
				C-3.3.1 (203,307)
				DATE
				SEP 2017
APPROVED BY:		9/17		