



**NOTES:**

**TYPICAL SECTION**  
NTS

1. SIZE AND PRESSURE CLASS AS INDICATED ON THE PLANS, SHALL BE DETERMINED BY THE DESIGN ENGINEER, MINIMUM SIZE 3/4 INCH. CORP BALL VALVE SHALL BE MUELLER B-20013 OR B-2969, OR FORD FB-500-x WITH MALE I.P. THREADS BOTH ENDS OR APPROVED EQUAL. ELBOW COUPLING SHALL BE MUELLER H-15533 FEMALE I.P. THREAD X CTS 110 COMP, OR FORD L14-xx-Q FEMALE IP THREAD X QUICK JOINT, W/ TUBING LINER OR APPROVED EQUAL. BALL CURB VALVE SHALL BE MUELLER B-25171N OR FORD B41-xxx-NL FEMALE I.P. X CTS 110 OR APPROVED EQUAL.
2. AIR RELEASE VALVES SHALL BE INSTALLED OUTSIDE PAVEMENT SECTION. SLOPE GROUND AWAY FROM AIR RELEASE VALVE BOX OR CONSTRUCT MINIMUM HEIGHT CURBING TO PROTECT FROM FLOODING BY SURFACE WATERS.
3. ALL PIPES SHALL HAVE POSITIVE SLOPE FROM MAIN LINE TO AIR RELEASE VALVE.
4. 1 1/2 INCH TO 2 INCH AIR-RELEASE VALVES REQUIRE A CHRISTY FL36 BOX AND COVER OR APPROVED EQUAL.
5. STEEL PIPE PAINT SHALL BE RUST-OLEUM 7400 HIGH GLOSS SAFETY YELLOW ALKYD ENAMEL OR APPROVED EQUAL.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	POST NOTE	9/17	<b>POTABLE WATER AIR RELEASE</b>	CARSON CITY
				DRAWING NO. C-3.1.10 (203,307)
				DATE SEP 2017
APPROVED BY:		9/17		