



**TYPICAL SECTION**  
NTS

**NOTES:**

1. ALL FITTINGS SHALL BE LOW LEAD CONTENT AND COMPLY WITH NSF 61 & NSF 372.
2. EXTEND TRACER WIRE AT LEAST 48" INTO METER BOX.
- 1 3. FORD A24-NL METER ADAPTOR SHALL BE USED TO SET 5/8" X 3/4" METER.
- 2 4. METER BOXES SHALL BE LOCATED OUTSIDE OF VEHICLE TRAFFIC AREAS AND PARKING SHALL NOT BE ALLOWED OVER A METER BOX.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	MISC	9/17	<b>1" SINGLE METER SET</b>	CARSON CITY
2	BOX SIZE	6/19		DRAWING NO. C-3.2.3.1 (203, 307)
				DATE JUNE 2019
APPROVED BY:		6/19		