



TYPICAL SECTION
NTS

NOTES:

1. ALL FITTINGS SHALL COMPLY WITH ANSI/NSF 372 REGARDING LOW LEAD CONTENT.
2. EXTEND TRACER WIRE AT LEAST 48" INTO METER BOX.
3. A 2 INCH METER SET REQUIRES A 2 INCH MINIMUM SERVICE LINE.
4. METER BOXES SHALL BE LOCATED OUTSIDE OF VEHICLE TRAFFIC AREAS AND PARKING SHALL NOT BE ALLOWED OVER A METER BOX.

NO.			REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1			NOTE 3	9/17	1 1/2" - 2" METER SET	CARSON CITY
2			TRAF RATING	6/19		DRAWING NO. C-3.2.5.1 (203, 307)
APPROVED BY:			6/19	DATE JUN 2019		